



Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16

Memo no.:FSR/0125186231300363

Date: 21-11-2023

From:
Director
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: HERITAGE COLLEGE OF EDUCATION
VILL. AND PO.-RABIBHAG, P.S.- BAGNAN, DIST.- HOWRAH, PIN- 711312(WB)

Sub: Fire Safety Certificate in respect of 1 no. G+3 storied educational building Heritage College of Education situated at Vill. + P.O.- Rabibhag, P.S.- Bagnan, Dist.- Howrah, West Bengal- 711312.

This is in reference to your application no. 0125189231300221 dated 19-09-2023 regarding the Fire Safety Certificate in respect of 1 no. G+3 storied educational building Heritage College of Education situated at Vill. + P.O.- Rabibhag, P.S.- Bagnan, Dist.- Howrah, West Bengal- 711312.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

- 1.The interior finish decoration of building shall be made with low flame spread material confirming I.S. specification.
- 2.To eliminate risk of Fire Hazard, good housekeeping both for inside and outside of the building shall be strictly maintained.
- 3.Existing electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them.
- 4.The notice of Fire Fighting and Evacuation from the building shall be prepared prominently and displayed at all vulnerable places of the building.
- 5.Contact number of Emergency Departments shall be displayed.
- 6.The security staffs and non teaching staffs shall be conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire & Testing.
- 7.Mock Fire practice and evacuation drill shall be performed periodically with participants of all the security personnel and residents of the building.
- 8.First Aid Fire Fighting system shall be provided as per I.S. specification.
- 9.Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installations and equipments in the building to keep them in perfectly good working condition at all the times.

10. Periodical flashing of water from the Yard Hydrants, Landing Valves and Hose Reel Hoses shall be made to maintain the efficient working performance.
11. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
12. Any deviation and failure in maintenance of the Fire Prevention and Fire Safety measures will be at the risk and liability of the Head of the Organization.
13. This Fire Safety Certificate is valid for three years and has to be renewed every interval of three years from the date of issue of this letter.

Signature valid

Digitally signed by ABHIJIT
PANDEY
Date: 2023.11.21 14:35:14 IST

DIRECTOR
West Bengal Fire & Emergency Services

Memo No.: FSR/0125186231300221